




<b>Licence</b>	11149	
<b>Link to Licence</b>	<a href="http://app.epa.nsw.gov.au/prpoeoapp/">http://app.epa.nsw.gov.au/prpoeoapp/</a>	
<b>Address</b>	Industrial Drive, Mayfield, NSW, 2304	
<b>Location of Monitoring Point/Area</b>	<b>Point 39</b>	
<b>Monthly Summary for: Sample Received</b>	<b>Oct-23</b> Sample received 9 th of October . Oil and Grease 4 th of October. Other daily and continuous measurements performed through October 2023.	
<b>Data Obtained</b>	07/11/2023	

Pollutant	Units of Measure	Monitoring frequency required by Licence	No of times measured during month	Min value	Max value	100 percentile limit	Exceedance (Y/N)	Comments
Nitrogen (ammonia)	mg/L	Monthly	1	N/A	<1	N/A	N	
Phosphorus	mg/L	Monthly	1	N/A	0.18	6	N	
Total Copper	micrograms/L	Monthly	1	N/A	5	N/A	N	
Total Iron	mg/L	Monthly	1	N/A	1.3	5	N	
Total Lead	micrograms/L	Monthly	1	N/A	<1	N/A	N	
Total Manganese	mg/L	Monthly	1	N/A	<0.1	0.5	N	
Total Suspended Solids	mg/L	Monthly	1	N/A	17	50	N	
Total Zinc	mg/L	Monthly	1	N/A	0.15	2.5	N	
Oil and Grease	mg/L	Monthly	1	N/A	7	20	N	
pH	pH	Continuous	Continuous	7.4	8.1	6.5-8.5	N	
Temperature	degrees Celsius	Continuous	Continuous	20.5	33	38	N	
Volume	kL/day	Daily	Daily	0	295*	200	N	

\*One wet weather discharge under Licence section L3.3.